

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 46902  
 Permit No. \_\_\_\_\_  
 Basin. 084

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17741

1. OWNER Rockwell International-Rocketdyne ADDRESS AT WELL LOCATION former Rockwell  
 MAILING ADDRESS Div 6633 Conaga Ave. Nevada field lab in Palamino Valley  
Conaga Park, CA 91303 Nevada 2646 Whiskey Springs Rd  
 2. LOCATION SE  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec. 07 T. 22N N/S R. 22E E. Washoe County  
 PERMIT NO. Waiver M/O-431-B 77-320-054 n/a Palamino J. Unit 11 7223  
 Issued by Water Resources Parcel No. Subdivision Name

3. PS-4/V-4 WORK PERFORMED Area D  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravelly Sand		0	12	fine
Gravelly Sand		12	25	f-cou
Gravelly Sand		25	37	med
Clayey Sand		37	49	v.fine
Gravelly Sand		49	57	cobbles

8. WELL CONSTRUCTION 55.5 Feet  
 Depth Drilled. 55.5 Feet Depth Cased. 55.5 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8.75 Inches To 0 Feet 57 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2-3/8	sch40	n/a	0	55.5 PS-4
1-5/16	sch80	n/a	2.3	43. V-4

Perforations: factory sawed  
 Type perforation \_\_\_\_\_  
 Size perforation .020  
 From 38.4 feet to 42.7 feet V-4  
 From 50.4 feet to 54.6 feet PS-4  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 34'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
with V-4 2' and PS-4 5' bentonite barrier  Concrete Grout  
 Gravel Packed:  Yes  No  
 From PS-4 36' 48' feet to 55.5' feet

9. WATER LEVEL 49.5 feet below land surface  
 Static water level: 49.5 feet below land surface  
 Artesian flow: n/a G.P.M. n/a P.S.I.  
 Water temperature n/a °F Quality n/a

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Hedman Drilling Co. Contractor  
 Address P.O. Box 726 Contractor  
Lincoln, CA 95648  
 Nevada contractor's license number 0033492  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1555  
 Division of Water Resources, the on-site driller.  
 Signed Steve Hedman  
 By driller performing actual drilling on site or contractor  
 Date 6/6/94

Date started 6/5/ 19 94  
 Date completed 6/6 19 94

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
n/a			