WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46405
Permit No.
Basin 084

NOTICE OF INTENT NO. 17741

1. OWNER Rockwell International-Rocketdyne Div
MAILING ADDRESS 6633 Conaga Ave.
Conaga Park, CA 91303

ADDRESS AT WELL LOCATION former Rockwell
Nevada field lab in Palamino Valley
Nevada 2640 Whiskey Springs Road

2. LOCATION SE ¼ NE ¼ Sec. 07 T. 22N N/S R. 22E E. Washoe County
PERMIT NO. WaiverM/O-431-B (Issued by Water Resources) 77-320-0549 (Parcel No.) n/a Palomino V. Unit 11 7 2 2 3 (Subdivision Name)

3. D-32A WORK PERFORMED Area D
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravelly Sand		0	38	f-course
Clayey Sand/Sandy clay		38	53	f-med
Gravelly Sand		53	58	f-course
Sand and Gravel		58	68	f-course
Tuff		68	72	unwelded

Date started 6/28, 19 94
Date completed 6/30, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
n/a			

8. WELL CONSTRUCTION
Depth Drilled 72 Feet Depth Cased 72 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10.75 Inches		0 Feet	72 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	sch40	n/a	0	64.5

Perforations:
Type perforation factory sawed
Size perforation .020
From 34.5 feet to 64.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 29'
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 31 feet to 72 feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout
with 2 'bentonite barrier

9. WATER LEVEL
Static water level 62.12 feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature n/a °F Quality n/a

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hedman Drilling Co. (Contractor)
Address P.O. Box 726 (Contractor)
Lincoln, CA 95648
Nevada contractor's license number issued by the State Contractor's Board 0033492
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1555
Signed Steve Hedman (By driller performing actual drilling on site or contractor)
Date 6/30/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627