

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26928

1. OWNER Farr Farms ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Star Route "Home Place" Reese Valley
Battle Mountain, NV 89820 Battle Mountain, NV 89820
 2. LOCATION SW 1/4 NE 1/4 Sec. 12 T 24 N R 40 E Lander County
 PERMIT NO. 20006
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------|--------------|------|-----|------------|
| Top soil | | 0 | 12 | 12 |
| Sand & gravel | | 12 | 54 | 42 |
| Sandy clay | | 54 | 56 | 2 |
| Sand & gravel | | 56 | 72 | 16 |
| Brown clay | | 72 | 88 | 16 |
| Sand & gravel | | 88 | 118 | 30 |
| Clay | | 118 | 125 | 7 |
| Clay, sand & gravel | | 125 | 135 | 10 |
| Pea gravel | | 135 | 141 | 6 |
| Brown clay | | 141 | 150 | 9 |
| Sand & gravel | | 150 | 153 | 3 |
| Brown clay & sand | | 153 | 156 | 3 |
| Sand & gravel | | 156 | 176 | 20 |
| Clay | | 176 | 180 | 4 |
| Sand & gravel | | 180 | 188 | 8 |
| Clay, sand & gravel | | 188 | 202 | 14 |
| Sand & gravel | | 202 | 212 | 10 |
| Clay & sand | | 212 | 217 | 5 |
| Sand & gravel | | 217 | 218 | 1 |
| Clay | | 218 | 228 | 10 |
| Sand & clay | | 228 | 231 | 3 |
| Sand & gravel | | 231 | 240 | 9 |
| Sand & clay streaks | | 240 | 305 | 65 |

8. WELL CONSTRUCTION
 Depth Drilled 305 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
20 Inches 0 Feet 55 Feet
18 Inches 55 Feet 305 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 16 | 42 | 1/4 | +2 | 130 |
| 16 | 42 | 1/4 | 250 | 260 |

Perforations:
 Type perforation Triple row mill slot
 Size perforation 3/16 X 2 1/2
 From 130 feet to 250 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 260 feet to 305 feet

9. WATER LEVEL
 Static water level 130 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started July 7, 1994
 Date completed July 7, 1994

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|-------------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift | <u>1800</u> | <u>180'</u> | <u>6</u> |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address P.O. Box 590 Contractor
Winnemucca, NV 89446
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1154
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7/14/94