

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24647

1. OWNER Alta Gold Company ADDRESS AT WELL LOCATION Antelope Valley  
 MAILING ADDRESS HC 10, Box 10050  
Ely, NV 89301  
 2. LOCATION SE 1/4 NW 1/4 Sec 4 T 26 N 68 E Elko County  
 PERMIT NO. 52895 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	10	10
Thin Bedded Sand & Gravel		10	392	382
Water Bearing Gravel	x	392	394	2
Thin Bedded Sand & Gravel		394	490	96
Water Bearing Gravel	x	490	494	4
Thin Bedded Sand & Gravel		494	510	16
Water Bearing Gravel	x	510	514	4
Thin Bedded Sand & Gravel		514	582	68
Water Bearing Sand & Gravel	x	582	584	2
Thin Bedded Sand & Gravel		584	606	22
Water Bearing Gravel	x	606	610	4
Thin Bedded Sand & Gravel		610	675	65
Massive Clay		675	703	28

8. WELL CONSTRUCTION  
 Depth Drilled 703 Feet Depth Cased 703 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 703  
14 3/4 Inches Feet Feet  
 \_\_\_\_\_ Inches Feet Feet  
 \_\_\_\_\_ Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28.04	.250	0	703

Perforations:  
 Type perforation Factory  
 Size perforation 3/16" x 2 1/2"  
 From 441 feet to 522 feet 10 row  
 From 522 feet to 683 feet 20 row  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50 ft.  
 Placement Method:  Pumped  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 703 feet

9. WATER LEVEL  
 Static water level 372 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 57 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Christiansen Drilling, Inc.  
 Address 557 Ely Avenue  
Ely, NV 89301  
 Nevada contractor's license number 14790  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641  
 Signed Jared D. Christiansen  
 By driller performing actual drilling on site or contractor  
 Date 9-20-94

Date started May 16, 19 94  
 Date completed July 11, 19 94

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>175</u>	<u>328</u>	<u>8</u>

'94 SEP 26 P 1:47  
 RECEIVED  
 STATE ENGINEERS OFFICE