

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24823

1. OWNER Milton Harlan ADDRESS AT WELL LOCATION same  
 MAILING ADDRESS 1356 S 395  
Gardnerville NV 89410  
 2. LOCATION SE 1/4 SW 1/4 Sec 7 T 10 R 22 E Douglas County  
 PERMIT NO. 37-110-02 none Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>dirt + rock</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>rock + boulders + clay</u>		<u>5</u>	<u>80</u>	<u>75</u>
<u>brn clay</u>		<u>80</u>	<u>85</u>	<u>5</u>
<u>rock + clay</u>		<u>85</u>	<u>135</u>	<u>50</u>
<u>rock + shale mix</u>	<u>x</u>	<u>135</u>	<u>160</u>	<u>25</u>

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
6 Inches 50 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation factory slotted + torch cut  
 Size perforation 3/32  
 From 100 feet to 140 feet  
 From 140 feet to 160 feet ← torch cut  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 115 feet below land surface  
 Artesian flow no G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature cold °F Quality good

Date started 7 1 1994  
 Date completed 7 13 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>18</u>	<u>10</u>	<u>12</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ed Miller Contractor  
 Address P.O. 92 Contractor  
Smith, NV 89444  
 Nevada contractor's license number 32166  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1806  
 Division of Water Resources, the on-site driller.  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 7-13-94