

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26530

1. OWNER LORENZO LARA ADDRESS AT WELL LOCATION Nevada
 MAILING ADDRESS 2012 CITY VIEW AVE
LOS ANGELES, CA 90033
 2. LOCATION SW 1/4 NW 1/4 Sec 7 T 34 N/S R 56 E ELKO County _____
 PERMIT NO. Lot 23, Blk. C Last Chance Ranch Unit #3
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silt</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Soft, sandy clay</u>		<u>2</u>	<u>12</u>	<u>10</u>
<u>Clay, cobbles & gravel</u>		<u>12</u>	<u>13</u>	<u>1</u>
<u>Soft, sandy clay</u>		<u>13</u>	<u>18</u>	<u>5</u>
<u>Boulders, cobbles, gravel</u>		<u>18</u>	<u>21</u>	<u>3</u>
<u>Shale, soft, gray</u>		<u>21</u>	<u>259</u>	<u>238</u>
<u>Sand</u>		<u>259</u>	<u>286</u>	<u>27</u>
<u>Gray-green shal</u>		<u>286</u>	<u>292</u>	<u>6</u>
			<u>T.D. 292</u>	

8. WELL CONSTRUCTION
 Depth Drilled 292 Feet Depth Cased 292 Feet
 HOLE DIAMETER (BIT SIZE)

From		To	
<u>1.0</u> Inches	<u>0</u> Feet	<u>1.00</u> Feet	
<u>8</u> Inches	<u>1.00</u> Feet	<u>2.86</u> Feet	
<u>6</u> Inches	<u>2.86</u> Feet	<u>2.92</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>	<u>12.92</u>	<u>.188</u>	<u>+1 1/2</u>	<u>292</u>

Perforations:
 Type perforation Torch cut
 Size perforation 1/8 x 4 x 2/ft
 From _____ feet to _____ feet
 From 2.5.9 feet to 2.8.7 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 292 feet

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 9-1 1994
 Date completed 9-6 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>15</u>	<u>45</u>	<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MUTH DRILLING CO Contractor
 Address 203 Pine St Contractor
Elko 89801
 Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
 Signed James V. Muth
 By driller performing actual drilling on site or contractor
 Date 9/6/94