

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25829

1. OWNER Doyle Tow ADDRESS AT WELL LOCATION Adade Summit  
 MAILING ADDRESS P.O. Box 5264 East of Hwy 225 North of Elko App  
Elko NV 89801 14 miles  
 2. LOCATION N.W. 1/4 SW 1/4 Sec. 35 T 36 N/S R. 54 Elko County  
 PERMIT NO. 05-530-14-2 Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Boulders</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>Cemented SANDSTONE</u>		<u>6</u>	<u>100</u>	<u>94</u>
<u>Hard Rock</u>		<u>100</u>	<u>101</u>	<u>1</u>
<u>Cemented SANDSTONE</u>		<u>101</u>	<u>185</u>	<u>84</u>
<u>Loose SANDSTONE</u>	<u>X</u>	<u>185</u>	<u>200</u>	<u>15</u>

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>1.88</u>	<u>12</u>	<u>200</u>

Perforations:  
 Type perforation slots  
 Size perforation 3/16 x 3"  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 52  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 52 feet to 200 feet

9. WATER LEVEL  
 Static water level 120 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fertig Drilling Co Contractor  
 Address P.O. Box 525 Contractor  
Elko NV 89801  
 Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Shel C Fertig  
 By driller performing actual drilling on site or contractor  
 Date 4-13-94

Date started 8-30, 1994  
 Date completed 9-6, 1994

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>35+</u>	<u>NV</u>	<u>5.5</u>	

194 SEP 16 P 12:24  
 STATE ENGINEERS OFFICE