WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46457
Permit No.
Basin 108

NOTICE OF INTENT NO 26893

1. OWNER Dave Little
MAILING ADDRESS P.O. Box 128
Yerington, NV 89447

ADDRESS AT WELL LOCATION
Minor Lane Yerington

2. LOCATION SW ¼ NW ¼ Sec. 27 T. 14 N/S R. 25 E Lyon County
PERMIT NO. 60013T (Issued by Water Resources) | NA (Parcel No.) | NA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	7	7
Gravel		7	12	5
Clay		12	14	2
Sand & gravel/clay		14	58	44
Brown clay/sand		58	73	15
Fine sand/gravel		73	90	17
Clay		90	98	8
Sand & gravel		98	147	49
Clay/small clay layers		147	170	53
Clay		170	187	17
Sand & gravel		187	203	16
Sandy clay		203	330	127
Sand		330	340	10
Sandy clay		340	380	40
Sand		380	400	20
Sandstone		400	405	5
Quartsite/sand/gravel		405	425	20
Centralizers at: 100'				
200'				
300'				
400'				
420'				

Date started June 22, 19 94
Date completed June 26, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3000	110'	8

8. WELL CONSTRUCTION
Depth Drilled 425 Feet Depth Cased 425 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
48 Inches		0 Feet	14 Feet
34 Inches		14 Feet	50 Feet
26 Inches		50 Feet	425 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	47.02	.250	+2	100

Perforations:
Type perforation 5 slots on mill slotted
Size perforation and Louvered
From ff 100'-140' feet to std flow 300'- feet 340'
From drms 140'-160' feet to ff 340'- feet 380'
From ff 160'-180' feet to drms 380'- feet 420'
From srms 180'-200' feet to feet
From drms 200'-300' feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 425 feet

9. WATER LEVEL
Static water level 25 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address P.O. Box 590 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed C. E. Epple (By driller performing actual drilling on site or contractor)
Date 7-19-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627