WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4448
Permit No.
Basin 671

NOTICE OF INTENT NO. 26178

1. OWNER Cliff Burns
MAILING ADDRESS 335 W. 4th Street
Winnemucca, Nevada 89445
ADDRESS AT WELL LOCATION Dove St.

2. LOCATION S.W. ¼ N.E. ¼ Sec. 8 T. 34 N. N/S R. 38 E. Pershing County
PERMIT NO. BLOCK F (Issued by Water Resources) | LOT #7 (Parcel No.) | Burns Acres (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Soil brown. | | 0 | 2 | 2 |
| Clay brown. | | 2 | 16 | 14 |
| Gravel brown. | | 16 | 51 | 35 |
| Gravely clay brown. | | 51 | 84 | 33 |
| Sand & gravel brown. | 26 | 84 | 110 | 26 |

'94 AUG 22 P 1:29 STATE ENGINEER

Date started June 25, 1994
Date completed July 16, 1994

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 30 | 2' | 2½ |

8. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 | Inches | 0 | Feet | 50 | Feet |
| 6 | Inches | 50 | Feet | 110 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 14 | .188 | 0 | 110 |

Perforations:
Type perforation Torch
Size perforation 1/8" by 5"
From 80' feet to 110' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 64' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 54 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T. & R. Drilling (Contractor)
Address P.O. Box 1982 (Contractor)
Winnemucca, Nevada 89446
Nevada contractor's license number issued by the State Contractor's Board 017721
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1190
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Aug. 16, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627