WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4c470
Permit No.
Basin 106

NOTICE OF INTENT NO. 27102

1. OWNER John Oscarson 4185
MAILING ADDRESS 4185 Kyle Dr. Wellington Nev. 89410
ADDRESS AT WELL LOCATION 4208 Kyle Dr. Wellington Nev. 89410

2. LOCATION SE ¼ NE ¼ Sec. 14 T. 10 N/S R. 22 E. Douglas County
PERMIT NO. none (Issued by Water Resources) 37-144-01 (Parcel No.) Topaz Ranch Estates (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy loam		0	3	3
hard pan		3	8	5
yellow sandy clay		8	72	64
sand + gravel	✓	73	87	14
yellow sandy clay		87	105	18
gravel		105	119	14
yellow sandy clay		119	127	8
gravel		127	142	15
pea gravel + large sand		142	170	28
yellow sandy clay		170	174	4
pea gravel + large sand		174	183	11
hard rock		183	185	2

Date started Aug 11, 1994
Date completed Aug 16, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15+	0	4

8. WELL CONSTRUCTION
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
6 Inches		50 Feet	185 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	185

Perforations:
Type perforation Factory saw slott
Size perforation 3/32 X 13
From 155 feet to 185 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller (Contractor)
Address Box 92 Smith Nev. 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date Aug 19 - 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627