WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46475
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 25786

1. OWNER Hendrix Properties
MAILING ADDRESS P.O. Box 1687
Fallon, NV 89407-1687

ADDRESS AT WELL LOCATION
660 Sunshine Loop
Fallon, NV 89406

2. LOCATION SW ¼ SE ¼ Sec. 6 T 18 N/S X R 29 E CHurchill County

PERMIT NO. | Issued by Water Resources | 006-741-72 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown CLay		0	5	5
Brown Sand		5	18	13
Brown Clay		18	22	4
Gray Sand		22	60	42
Black CLay		60	67	7
Black Sand		67	87	20
Grey Sand		87	100	13
Brown Sand	X	100	114	14
Brown Clay		114	115	1

'94 SEP 30 P12:59
STATE ENGINEER'S OFFICE

Date started 8-19, 1994
Date completed 8-23, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 115 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet	
7½ Inches	50 Feet	115 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	115

Perforations:
Type perforation well screen
Size perforation .030
From 112 feet to 115 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 115 feet

9. WATER LEVEL
Static water level 12' 2" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date 9-1-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627