

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20489

1. OWNER Robert D. Stitser ADDRESS AT WELL LOCATION 7420 W. 4th. St. #2
 MAILING ADDRESS P.O. Box 6627 Reno, Nv. 89523
 2. LOCATION SE 18 T 19 N 19 E Washoe County
 PERMIT NO. 005057 Issued by Water Resources Parcel No. 39-290-23 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Bolders w/s clay cement rock and brown clay		0	35	
Clay w/s cement rock		35	100	
Clay w/s cement rock		100	120	
Clay w/s black clay and brown		120	140	
		140	145	
		145	160	
		160	180	
Clay and cement rock w/s black clay		180	260	
Brown and green clay w/s fracture rock		260	320	
		320	340	
		340	380	
		380	440	
Brown and green clay w/s sand		440	783	

8. WELL CONSTRUCTION
 Depth Drilled 783 Feet Depth Cased 783 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10" Inches 0 Feet 783 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	n/a	.188	+1	783

Perforations:
 Type perforation Factory
 Size perforation 1/8 by 3"
 From 383 feet to 783 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 125' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 783 feet to 125 feet

9. WATER LEVEL
 Static water level 57 feet below land surface
 Artesian flow n/a G.P.M. _____ P.S.I. _____
 Water temperature 60.0 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Dave McNinch Contractor
 Address P.O. Box 585
Winnemucca, Nv. 89446
 Nevada contractor's license number 5437
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 730
 Division of Water Resources, the on-site driller.
 Signed Gerald Lee Mump
 By driller performing actual drilling on site or contractor
 Date 8/10/1994

Date started May 26, 1994, 19____
 Date completed June 14, 1994, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	n/a	6 hrs.