

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24922

1. OWNER RICH LISKA ADDRESS AT WELL LOCATION PINE NUT RD  
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION NE 1/4 SE 1/4 Sec. 1 T. 11 N. R. 21 E DOUGLAS County  
 PERMIT NO. 35-080-33 PINE NUT MTS. Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Aluvial <u>1/4</u> sandy clay		0	45	45
Fractured silt stone		45	63	18
Aluvial <u>1/4</u> sandy clay		63	68	5
Fractured silt stone		68	147	79
Sandy clay		147	153	6
Silt stone		153	171	18
Aluvial <u>1/4</u> sandy clay		171	178	7
Silt stone		178	193	15
Aluvial <u>1/4</u> sandy clay		193	234	41
Silt stone		234	245	11
Aluvial <u>1/4</u> sandy clay		245	272	27
Silt stone		272	281	9
clay <u>1/4</u> coarse sand		281	385	104
cemented Aluvial		385	415	30
Silt stone		415	419	4
cemented Aluvial		419	480	61
fractured diorite	<u>8x</u>	480	513	33
diorite		<del>513</del>	515	2
		513		

8. WELL CONSTRUCTION  
 Depth Drilled 515 Feet Depth Cased 515 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 180 Feet  
8 1/2 Inches 180 Feet 515 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>1.88</u>	<u>0</u>	<u>515</u>

Perforations:  
 Type perforation Factory slotted / T.C.  
 Size perforation 3 x 3/32  
 From T.C. 475 feet to 495 feet  
 From Factory 495 feet to 515 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 515 feet

9. WATER LEVEL  
 Static water level 420 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD  
FALLON, NV 89406  
 Nevada contractor's license number 27673  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
 Signed Jerald W. Whinnell  
 By driller performing actual drilling on site or contractor  
 Date 7-29-94

Date started 6-16, 1994  
 Date completed 7-29, 1994

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>10</u>		<u>10</u>