

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 24938

1. OWNER MR + MRS GANETTI ADDRESS AT WELL LOCATION 521 CENTERVILLE
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION NW 1/4 NE 1/4 Sec 14 T 12 N R 19 E DOUGLAS County
 PERMIT NO. 19-212-07 CENTERVILLE
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other M.D.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	4	4
Grey sand gravel ^{some} clay		4	25	21
Grey clay DE		25	65	40
DG w/short brn clay strks		65	79	14
Dark brn. Sandy clay		79	84	5
DG w/short brn clay strks		84	98	14
DG		98	120	22
DG w/short brn clay strks		120	159	39
DG w/ sandy clay		159	173	14
DG w/short brn clay strks	<u>NA</u>	173	200	27
		173		

79 AUG 15 4:03
 STATE REGIONAL

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>200</u>

 Perforations:
 Type perforation Factory slotted
 Size perforation 31.3/22
 From 180 feet to 200 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 200 feet

9. WATER LEVEL
 Static water level Artesian feet below land surface
 Artesian flow 4 G.P.M. P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC
 Contractor
 Address 7780 CURRY RD
 Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Jerald W. Phinell
 By driller performing actual drilling on site or contractor
 Date 8-8-94

Date started 8-2 1994
 Date completed 8-8 1994

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>		<u>1</u>