

OFFICE USE ONLY
 Log No. 16500
 Permit No. 1057
 Basin. 1057

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26566
 ADDRESS AT WELL LOCATION 978 FERRIERE CT
GARDNERVILLE

1. OWNER CANTRELL CONST., INC ADDRESS AT WELL LOCATION 978 FERRIERE CT
 MAILING ADDRESS P.O. BOX 1023
MINDEN, NV 89423
 2. LOCATION SE 1/4 SE 1/4 Sec. 13 T. 12 N. S. R. 20 E DOUGLAS County
 PERMIT NO. 29-442-01 3A Parcel No. RUHENSTROTH Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/GRAVEL		0	14	14
SANDY CLAY		14	82	68
CEMENTED GRAVEL		82	135	53
SANDY CLAY w/GRAVEL		135	141	6
CEMENTED GRAVEL		141	203	62
SANDY CLAY w/GRAVEL		203	208	5
CEMENTED GRAVEL	✓	208	239	31
SAND + GRAVEL	✓	239	245	6
CEMENTED GRAVEL		245	250	5

94 AUG 15 P 4:03
 STATE ENGINEER'S

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet
 HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 250 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>250</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 230 feet to 250 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 250 feet

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 7-25, 1994
 Date completed 7-29, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>10+</u>	<u>-</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD
FALLON, NV 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Paul J. Mooy
 By driller performing actual drilling on site of contractor
 Date 7-29-94