

OFFICE USE ONLY
 Log No. 46553
 Permit No. _____
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26559

1. OWNER NEVADA JOHNSON ADDRESS AT WELL LOCATION 1903 ARABIAN
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION SW 1/4 NE 1/4 Sec. 24 T. 12 N. R. 20 E. DOUGLAS County
 PERMIT NO. 29-480-48 Parcel No. _____ Subdivision Name RUHENSTROTH

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	25	25
CEMENTED GRAVEL		25	47	22
SANDY CLAY w/GRAVEL		47	54	7
CEMENTED GRAVEL		54	61	7
CLAY		61	78	17
CEMENTED GRAVEL		78	92	
SANDY CLAY w/GRAVEL		92	96	4
CEMENTED GRAVEL		96	110	14
SANDY CLAY		110	115	5
CEMENTED GRAVEL	✓	115	160	45

94 AUG 15 14:04
 STATE ENGINEERING

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Pat J. Moore
 By driller performing actual drilling on site or contractor
 Date 7-6-94

Date started 6-28, 1994
 Date completed 7-6, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>15+</u>	<u>-</u>	<u>2</u>