WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46506
Permit No.
Basin 087

NOTICE OF INTENT NO. 26286

1. OWNER Donna Traver
MAILING ADDRESS 3990 Rewana Way Reno, NV
ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼ NE ¼ Sec. 30 T. 19 N/S R. 20 E. Washoe County
PERMIT NO. Issued by Water Resources
Parcel No. 25-242-01
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
This was a 3½" well in a building Tom Gallager gave us a verbal waver to cement it from the bottom up. We Tagged bottom at 50' with our Tremie pipe then circulated the well with water to make sure there wasn't any thing in it and there wasn't then we pump in 25 sacks of neat cement till we got cement returns				

Date started 8/5/, 1994
Date completed 8/5/, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
3½			0	50'

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured 25 Sacks
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 4' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling (Contractor)
Address 2290 Pioneer Drive (Contractor)
Reno, Nevada 89509
Nevada contractor's license number issued by the State Contractor's Board 14170
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1261
Signed Steve [illegible] (By driller performing actual drilling on site or contractor)
Date 8/9/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627