

OFFICE USE ONLY
 Log No. 46513
 Permit No. 179
 Basin. 179

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23239

1. OWNER James Stella ADDRESS AT WELL LOCATION 4th E. Lot 8 Crosstimber Sub.
 MAILING ADDRESS P.O. Box 1163 Elko NV 89301

2. LOCATION SW 1/4 NW 1/4 Sec. 14 T. 17 N/S R. 63 E. White Pine County White Pine
 PERMIT NO. N/A Parcel No. 5-591-63 Subdivision Name Crosstimbers

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
top soil		0	2.5	
sand gravel clay		2.5	40	
clay		40	42	
gravel conglomerate		42	64	
clay		64	70	
gravel	water	70	71	
clay		71	72	
gravel	water	72	95	
clay		95	115	
gravel	water	115	118	
clay		118	124	
gravel	water	124	130	

8. WELL CONSTRUCTION

Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10</u> Inches	<u>0</u> Feet	<u>50</u> Feet
<u>8</u> Inches	<u>50</u> Feet	<u>80</u> Feet
<u>6</u> Inches	<u>80</u> Feet	<u>130</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.9</u>	<u>.187</u>	<u>-1</u>	<u>130</u>

Perforations:
 Type perforation mill
 Size perforation 8 x 2.5" x 6 row
 From 88' feet to 130 feet
 From 88' feet to 130 feet
 From 88' feet to 130 feet
 From 88' feet to 130 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50'
 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 80 feet

9. WATER LEVEL
 Static water level 64 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 64 °F Quality good

Date started June 10, 1994
 Date completed July 6, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>0</u>	<u>1 hr</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Nathan R Maynard Contractor
 Address P.O. Box 176 Land NV. 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0022864
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Nathan R Maynard
 By driller performing actual drilling on site or contractor
 Date July 28 94