

OFFICE USE ONLY
 Log No. 46515
 Permit No. _____
 Basin. 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25957

1. OWNER Julius Bunkowski ADDRESS AT WELL LOCATION 46 Jessen Rd
 MAILING ADDRESS P.O. Box 718 Wellington NV. 89444
Carson City NV. 89700
 2. LOCATION SW 1/4 SE 1/4 Sec. 25 T 12 N S R 23 E Lyon County
 PERMIT NO. 10-111-17 Parcel No. _____ Subdivision Name Smith Valley

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow Sand		0	4	4
Dk Coarse Sands		4	46	42
Brown Clay		46	87	41
Brown Dk Sands w/ clay seems		87	110	23
Coarse Dk Sands	XX	110	160	50
Silty Gray Clay seems		160	183	23
Gray Clay		183	210	27
Obsidian Gravels	XXV	210	220	10
Black Clay		220		
T.D. 220				
GPM 60+				

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 10 Feet
10 Feet 220 Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>11.90</u>	<u>.188</u>	<u>0</u>	<u>220</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 X 3/32
 From 120 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 220 feet

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. 60+ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.H. Pump Co. Contractor
 Address 5551 Hwy 50 E #3 Contractor
Carson City NV. 89701
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael L. Haek
 By driller performing actual drilling on site or contractor
 Date 8-3-94

Date started 7-27 1994
 Date completed 8-1 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>60+</u>	<u>6.5</u>	<u>7 HRS</u>