

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22901

1. OWNER THOMAS NEIVELL ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. BOX 30521 60 SILVERWOOD ROAD
SPARKS, NV 89431 RENO

2. LOCATION SE 1/4 SE 1/4 Sec. 22 T. 22 N/S R. 19 E. WASHOE County _____
 PERMIT NO. (5031 waco) 079-500-2551 Red Rock Estates #243 part 3
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	107	
DECOMPOSED GRANITE		107	165	
SANDY CLAY		165	171	
DECOMPOSED GRANITE		171	203	
CLAY		203	205	
DECOMPOSED GRANITE		205	231	
CLAY		231	252	
DECOMPOSED GRANITE	XX	252	305	

8. WELL CONSTRUCTION
 Depth Drilled 305 Feet Depth Cased 305 Feet

HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 305 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>.188</u>	<u>-1</u>	<u>305</u>

Perforations:
 Type perforation MILL SLOT
 Size perforation 1/8 x 3
 From 245 feet to 245 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50+ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 305 feet

Date started 6-29 1994
 Date completed 7-1 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>APPROX</u>	<u>100</u>	<u>300'</u>	<u>2</u>

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow NONE G.P.M. NONE P.S.I.
 Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EMDICO DRILLING Contractor
 Address P.O. BOX 3056 Contractor
RENO, NV 89509
 Nevada contractor's license number 32166-C23
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1418
 Division of Water Resources, the on-site driller.
 Signed Bruce Miller
 By driller performing actual drilling on site or contractor
 Date 7-15-94