

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22984

1. OWNER JIM STEWART ADDRESS AT WELL LOCATION 15255 ELKHORN Lane  
 MAILING ADDRESS 1128 LA VIA WAY RENO NV  
SPARKS NV 89434  
 2. LOCATION NW 1/4 SW 1/4 Sec 23 T 22 R 19 E WASHOE County  
 PERMIT NO. 079-470-61 Parcel No. RSC ROCK ESTATES #184 par. 1 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SINCE WELL HAD 190' OF 4" I.D. PVC PERFORATED CASING, WE JUST INSTALLED 205' FEET OF 1 1/2" GALVANIZED TRENCH PIPE, CIRCULATED VERY THICK BENTONITE TO THE SURFACE THEN PULLED ALL BUT 63' OF TRENCH PIPE AND CIRCULATED NEAT CEMENT TO SURFACE. WE PULLED THE 63' OF TRENCH PIPE OUT AND TOPPED OFF WITH A 5 GALLON BUCKET OF NEAT CEMENT. WENT BACK THE NEXT DAY AND TOPPED OFF WITH 10 GALLONS OF NEAT CEMENT MIXED IN A 5 GALLON BUCKET.				
WELL WAS ABANDONED BECAUSE IT PUMPED TOO MUCH FINE SAND				
See also log # 40643				

8. WELL CONSTRUCTION  
 Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	PVC	SCH 40	10	205
6.93	13	1.88	-1	205

Perforations:  
 Type perforation WELL SLOT  
 Size perforation 1020  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 7-9, 1994  
 Date completed 7-10, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EMOLCO DRILLING Contractor  
 Address P.O. BOX 8056 Contractor  
RENO NV 89507  
 Nevada contractor's license number 32166-C23  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418  
 Signed Bruce Miller  
 By driller performing actual drilling on site or contractor  
 Date 7-15-94