BW-15

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46536
Permit No. 55143
Basin 061

NOTICE OF INTENT NO. 26225

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NW ¼ SW ¼ Sec 24 T 36 N/S R 49 E EUREKA County

PERMIT NO. 55143 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARD BLACK ROCK		1630	1805	175
FRACTURED ROCK		1805	1915	110
HARD BLACK ROCK		1915	1970	55
FRAMCTURED ROCK		1970	2000	30
HARD BLACK ROCK		2000	2080	80

Date started MAY 10, 19 94
Date completed JUNE 3, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 2080 Feet Depth Cased 2080 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
39 Inches	0 Feet	22 Feet	
29 Inches	22 Feet	1630 Feet	
19 Inches	1630 Feet	2080 Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
32	127	.375	0	22
20	78.6	.375	22	1623
16	LOUVERED	.375	1460	2080

Perforations:
Type perforation LOUVERED
Size perforation 1/8"
From 1460 feet to 2080 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 1620 feet

9. WATER LEVEL
Static water level 1181 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 131 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1800

Signed [signature] (By driller performing actual drilling on site or contractor)
Date Aug 5, 1994

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627