WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46556
Permit No.
Basin 101

NOTICE OF INTENT No. 26507

1. OWNER Michelle Check
MAILING ADDRESS 1945 Clearview Court
Fallon, NV 89406

ADDRESS AT WELL LOCATION 1945 Clearview Court
Fallon, NV 89406

2. LOCATION NW ¼ NE ¼ Sec. 24 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. Issued by Water Resources
008-261-35 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	10	10
Brown Clay		10	18	8
Brown Sand		18	28	10
Gray Sandy Clay		28	34	6
Gray Sand		34	43	9
Black Clay		43	55	12
Fine Green Sand		55	70	15
Gray Coarse Sand		70	94	24
Brown Clay		94	97	3
Coarse Brown Sand	X	97	120	23

Date started July 27, 19 94
Date completed July 28, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	120

Perforations:
Type perforation Mill Cut
Size perforation 178
From 117 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.
Contractor
Address P.O. Box 1265
Contractor
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
By driller performing actual drilling on site or contractor
Date 7-13-94

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627