

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26358

1. OWNER R. Getto Const ADDRESS AT WELL LOCATION 1840 Rice
 MAILING ADDRESS _____

2. LOCATION NE 1/4 SW 1/4 Sec 24 T 19 N/S R 28 E Churchill County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand	✓	0	13	13
Brown Clay	✓	13	16	3
Silty Sand	✓	16	34	18
Black Sand	✓	34	40	6
Black silt	✓	40	56	16
Grey Clay	✓	56	63	7
Grey Gravel	✓	63	78	15
Brown Clay	✓	78	80	2
Sand	✓	80	86	6

8. WELL CONSTRUCTION
 Depth Drilled 96 Feet Depth Cased 96 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 5 Feet 50 Feet
6 Inches 50 Feet 96 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.185</u>	<u>11</u>	<u>56</u>

Perforations:
 Type perforation Machine Slot
 Size perforation .080
 From _____ feet to _____ feet
 From 67 feet to 94 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 13-8 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started MAY 27, 1994
 Date completed MAY 27, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>1</u>	<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Welsco Contractor
 Address Box 888 Contractor
FALLON NV.
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
 Signed W. D. B. [Signature]
 by driller performing actual drilling on site or contractor
 Date MAY 29 1994