WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46564
Permit No.
Basin 101

NOTICE OF INTENT NO. 27029

1. OWNER Richard Oakland
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5130 River Edge

2. LOCATION SE ¼ NW ¼ Sec. 28 T 19 N/S R 28 E ~~Lard~~ Churchill County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 15 | 15 |
| Grey Sand | ✓ | 15 | 20 | 5 |
| Brown Sand | ✓ | 20 | 40 | 4 |
| Coarse Black Sand | ✓ | 40 | 67 | 27 |
| Dark Gravel | ✓ | 67 | 73 | 6 |
| Brown Gravel | ✓ | 73 | 86 | 13 |

Date started June 28, 1994
Date completed June 28, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 30 | | 1 |

8. WELL CONSTRUCTION
Depth Drilled 86 Feet Depth Cased 86 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 Inches | | 0 Feet | 50 Feet |
| 6 Inches | | 50 Feet | 86 Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.9 | .188 | +1 | 86 |

Perforations:
Type perforation Machine slot
Size perforation .080
From feet to feet
From 79 feet to 84 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 12 – 1 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Contractor
Address Box 888 Contractor
Fallon
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed [signature] By driller performing actual drilling on site or contractor
Date June 27-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627