

OFFICE USE ONLY  
Log No. \_\_\_\_\_  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22-963

1. OWNER David & Tawnya Hendrix ADDRESS AT WELL LOCATION 18 N 100 E  
MAILING ADDRESS Po Box 12 Lund NV 89317

2. LOCATION SE 1/4 NE 1/4 Sec 33 T 12 N/S R 62 E White Pine County  
PERMIT NO. N/A Parcel No. 6-023-01 Subdivision Name Lund town site survey

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy top soil		0	4	
Sandy clay		4	10	
fine gravel con.		10	13	
clay		13	15	
gravel		15	20	
clay conglomerate		20	25	
gravel con.		25	30	
gravel clay con.		30	36	
clay		36	37	
gravel con.		37	38	
clay con.		38	42	
gravel con		42	51	
clay		51	54	
gravel	water	54	55	
clay		55	65	
clay		65	70	
gravel	water	70	73	
clay gravel con		73	75	
gravel	water	75	76	
clay con		76	78	
gravel	water	78	80	
clay con.		80	90	
gravel	water	90	92	
Sandy clay		92	100	
gravel	water	100	101	
clay con		101	108	
gravel	water	108	109	
Sandy clay		109	118	
gravel	water	118	120	

8. WELL CONSTRUCTION  
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 Inches	0 Feet 50 Feet
8 Inches	50 Feet 120 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 3/8	12.9	.188	-1	120

Perforations:

Type perforation MILL  
Size perforation 8 x 2.5 x 6 row

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 57 feet to 78 feet  
From 79 feet to 120 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 120 feet

9. WATER LEVEL  
Static water level 45' feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Nathan R Maynard Contractor  
Address Po Box 176 Lund NV 89317 Contractor

Date started Nov 14 1974  
Date completed Dec 8 1974

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35</u>	<u>5'</u>	<u>1 hr.</u>

Nevada contractor's license number issued by the State Contractor's Board 0022869  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556  
Signed Nathan Maynard  
By driller performing actual drilling on site or contractor  
Date Dec 20 1974