



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2595

1. OWNER REA MINING CORPORATION ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1190 AVE E 37 MILES SOUTH WEST OF ELY
EAST ELY, NEVADA 89405 ELY, NEVADA
 2. LOCATION SW 1/4 SW 1/4 Sec. 15 T. 16 N/S R. 57 E WHITE PINE County
 PERMIT NO. 55046 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARD GRAY ROCK		0	152	152
HARD GRAY ROCK WITH CLAY LAYERS		152	160	8
HARD BLACK AND GRAY ROCK		160	178	18
GRAY, GREEN, BLACK HARD ROCK		178	200	22
HARD GREEN ROCK		200	233	33
HARD BROWN FRACTURED ROCK		233	329	96
LOOSE FRACTURED ROCK		329	333	4
HARD BROWN ROCK		333	375	42
GRAY CLAY		375	383	8
HARD BROWN ROCK WITH FRACTURES AND CLAY		383	396	13
RUST STAINED HARD BROWN ROCK		396	405	9
HARD GREEN ROCK		405	490	85
HARD GRAY ROCK		490	520	30
HARD GRAY AND GREEN ROCK		520	685	165
HARD DARK BROWN ROCK		685	705	20
HARD GRAY AND GREEN ROCK		705	875	170
GREEN AND WHITE FRACTURED ROCK		875	910	35

8. WELL CONSTRUCTION
 Depth Drilled 900 Feet Depth Cased 888 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
20 Inches 0 Feet 50 Feet
12 1/2 Inches 50 Feet 900 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	22.36	.250	+1	388
14	54.57	.375	0	50

Perforations:
 Type perforation HY-CAP WIRE SCREEN LOUVERED
 Size perforation .250 AND .170
 From 888 feet to 788 feet
 From 788 feet to 388 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 94 OCTOBER 4, 19.94.
 Date completed DECEMBER 8, 19.94.

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	140	24

9. WATER LEVEL
 Static water level 663 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name SARGENT IRRIGATION COMPANY
 Contractor
 Address 9955 NORTH VIRGINIA STREET
 Contractor
RENO, NEVADA 89506
 Nevada contractor's license number issued by the State Contractor's Board 0021246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1593
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date DECEMBER 19, 1994