

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 46389
 Permit No. 081
 Basin 2160

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2160

1. OWNER Boyles Bros Drilling Co. ADDRESS AT WELL LOCATION Boyles Bros.
1707 S. 4490 W. 975 Industrial Way
Salt Lake City, Utah 84125 Sparks, Nevada 89431

2. LOCATION NE 1/4 SW 1/4 Sec. 8 T. 19 N/R. 20 E. Wahoe County
 PERMIT NO. MO-605A 34-401-02 Industrial Park
Issued by Water Resources Parcel No. Subdivision Name mu-8

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Pulled well cap from asphalt, cut PVC 2' below ground. Used 1/3 bag cement with 2 gal water to fill well hole, covered hole with 20" concrete then 4" asphalt cap to match parking lot.				
Original depth of hole - 24'				
Static water level - 13'				
Casing not pulled, back filled and the top 2' cut off - variance granted.				
Hole poured with cement thru a tremmie pipe.				
194 OCT 25 AM 11:11 STATE ENGINEERS				

8. WELL CONSTRUCTION
 Depth Drilled 24 Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 24 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured -tremmie Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 13 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 10/14, 19 94
 Date completed 10/14, 19 94

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Boyles Bros. Drilling Co. Contractor
 Address 1707 S. 4490 W. Contractor
Salt Lake City, Utah 84125
 Nevada contractor's license number issued by the State Contractor's Board 5380
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1883
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 10-17-94