WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46597
Permit No.
Basin 092B

NOTICE OF INTENT NO. 22864

1. OWNER DOUG BALEY
MAILING ADDRESS 3993 River Haven
Reno, Nevada 89509

ADDRESS AT WELL LOCATION 11815 Chesapeak
Reno, Nevada 89506

2. LOCATION NE ¼ SW ¼ Sec. 15 T 21N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 080-351-05 (Parcel No.) Lemmon Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	6	5
SAndy brown clay		6	19	13
Brown clay		19	36	17
Soft zone (NO WATER)		36	40	4
Brown clay		40	51	11
Soft zone (NO WATER)		51	56	5
Brown clay		56	79	23
Soft zone (NO WATER)		79	81	2
Brown sandy clay		81	116	35
Soft zone	X	116	129	13
Brown clay		129	138	9
Soft zone	X	138	143	5
Brown clay		143	155	12
Soft zone	X	155	160	5
Soft ~~xxxx~~ sandy clay		160	165	5

Date started 12-2-94, 19
Date completed 12-2-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18		

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	165	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	165

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 121 feet to 161 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 165 feet

9. WATER LEVEL
Static water level 86 feet below land surface
Artesian flow G.P.M. 18 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date December 5, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627