WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41600
Permit No.
Basin 349

NOTICE OF INTENT No 29095

1. OWNER KL PARTNERSHIP
MAILING ADDRESS 609 ASH ST.
ELKO, NV 89801

ADDRESS AT WELL LOCATION SW corner of 26th ST. & Pueblo Ave.

2. LOCATION SW ¼ SW ¼ Sec. 19 T. 35 N/S R. 56 E. ELKO County

PERMIT NO. (Issued by Water Resources) 36-013-01 (Parcel No.) Meadow Valley Ranchos #4 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Brown Clay		2	30	28
Brown Siltstone		30	200	170
Boulders & Siltstone		200	225	25
Brown Siltstone & pea gravel	X	225	270	45

'94 DEC 28 A10:36
STATE ENGINEER

Date started 12-8, 1994
Date completed 12-9, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		4

8. WELL CONSTRUCTION
Depth Drilled 270 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	270 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1½	270

Perforations:
Type perforation Millslot
Size perforation 3/16 X 3
From feet to feet
From 250 feet to 270 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 Per Telcon w/Hackworth
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 270 feet

9. WATER LEVEL
Static water level [redacted] 145' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. BOX 850 (Contractor)
ELKO, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12-16-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627