WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4645
Permit No.
Basin. 10

NOTICE OF INTENT NO. 26790

1. OWNER Gary & Jassia Ruggles
MAILING ADDRESS P.O. Box 391 Dayton NV 89403
ADDRESS AT WELL LOCATION 7037 Hwy 50 E Dayton NV 89403

2. LOCATION NW ¼ NW ¼ Sec. 27 T. 17 N/S R. 22 E. Lyon County
PERMIT NO. Issued by Water Resources | 19-221-03 Parcel No. | Pinenut View Estates #3 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
Soft Blow Sands		4	23	19
Course Sands & Gravels		23	64	41
Brown Clay		64	87	23
Course Sands		87	106	19
Course Obsidian Gravels w/water	XXX	106	160	54
TD 160				
GPM 35				

94 DEC -5 A11:20 STATE ENGINEER'S OFF

Date started 11-30, 19 94
Date completed 12-2, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	30	4 HRS

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.75	.188	0	160

Perforations:
Type perforation Mill Slot
Size perforation 3 X 3/32
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. 35 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company (Contractor)
Address 5551 Hwy 50 E #3 Carson City NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Tibek (By driller performing actual drilling on site or contractor)
Date 12-5-94

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY