REPORT NO. 94.89

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 46626
PERMIT NO.
BASIN 088

NOTICE OF INTENT NO. 28032

1. OWNER Clifford & Betty Sammis
MAILING ADDRESS 785 Andrew Lane Reno, Nv 89511

ADDRESS OF WELL 785 Andrew Lane
Reno, Nv 89511

2. WELL LOCATION NE 1/4 NW 1/4 SEC. 09 T 17N R 20 E Washoe COUNTY

PERMIT NO. R-231 PARCEL NO 17-342-20 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
SEE NOTES				

Notes: Pumped neat cement from 24' to surface as per Waiver #R-231. 1,757.7 lbs cement used.

Date Started 11/9/94 Date Completed 11/9/94

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [ ] Air Lift

GPM	DRAWDOWN	TIME (HRS)

8. WELL CONSTRUCTION

Depth Drilled _____ Depth Cased _____

HOLE DIAMETER (BIT SIZE)
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To
6		10 ga	-6	24

PERFORATIONS:
Type Perforation _____ Size Perforation _____
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth 24'
PLACEMENT METHOD: [X] Pumped [ ] Poured

SEAL TYPE:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

GRAVEL PACKED: [ ] Yes [X] No
From _____ Feet to _____ Feet

9. WATER LEVEL
Static Water Level Dry Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature _____ F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 625 Spice Islands Dr Ste L
Sparks, Nv 89431

NV. CONTRACTOR'S LIC. NO. 15291
DRILLER'S LIC. NO. ON SITE 1511

Signed [signature]
By driller performing actual drilling on site for contractor

Dated 11/11/94

'94 NOV 15 AM 11 22
STATE ENGINEER