WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46631
Permit No.
Basin 087

NOTICE OF INTENT NO. 22861

1. OWNER NAZIR ANSARI
MAILING ADDRESS 4430 Fairview
Reno, Nevada 89511

ADDRESS AT WELL LOCATION 25 Cassas Crt.
Reno, Nevada 89511

2. LOCATION SW ¼ SE ¼ Sec. 2 T. 18N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 041-120-63 (Parcel No.) SW Reno (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil with boulder		0	1	1
Gray sandy clay		1	8	7
Gray volcanic boulder		8	12	4
Gray sandy clay		12	28	16
Gray volcanic rock		28	61	33
Brown volcanic rock		61	89	27
Reddish brown volcanic rock, some clay streaks		89	101	12
Gray volcanic rock		101	128	27
Fracture, brown to red rock	X	128	131	3
Multi-color volcanic rock		131	149	18
Fracture rock	X	149	168	19
Reddish brown volcanic rock		168	175	7

Date started 11-10-94, 19
Date completed 11-11-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	100
8 5/8	100	175

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	175

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 130 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 175 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. 35 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed (By driller performing actual drilling on site or contractor)
Date November 14, 1994

NOV 18 '94 A1:11 RECEIVED STATE ENGINEER'S OFF.

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627