WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46633
Permit No.
Basin 085

NOTICE OF INTENT NO. 27311

1. OWNER: MIKE BARNETT
MAILING ADDRESS: 525 Mogul Mtn Drive, Reno, NV 89523
ADDRESS AT WELL LOCATION: 340 Descanso, Sparks, NV 89436

2. LOCATION: SW ¼ SW ¼ Sec. 1 T. 21N N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) | Parcel No. 076-281-23 | Subdivision Name: Spanish Springs

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Brown clay		3	9	6
Brown clay, some gravels		9	18	9
Weathered volcanic rock		18	21	3
Gray volcanic rock(hard)		21	88	67
Fracture (NO WATER)		88	89	1
Gray volcanic rock(hard)		89	221	132
Fracture rock(NO WATER)		221	247	26
Gray volcanic rock(HARD)		247	281	34
Fracture (apprx. 3 GPM)	X	281	282	1
Gray volcnic rock		282	329	47
Fracture rock (2 GPM)	X	329	338	9
Gray volcanic rock		338	357	19
Fracture rock (13 GPM)	X	357	371	14
Gray volcanick rock		371	375	4

Date started 11-1-94, 19
Date completed 11-4-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18		

8. WELL CONSTRUCTION
Depth Drilled 375 Feet Depth Cased 375 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	375 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	375

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 275 feet to 295 feet
From 310 feet to 330 feet
From 350 feet to 370 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 53 feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 53 feet to 375 feet

9. WATER LEVEL
Static water level 250 feet below land surface
Artesian flow G.P.M. 18 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date November 8, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627