

OFFICE USE ONLY
 Log No. 46652
 Permit No. _____
 Basin. 094

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27313

1. OWNER PETE & CHRIS ETCHEVERRY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. BOX 60446 300 Britt Road
Reno, Nevada 89504 Reno, Nevada 89506
 2. LOCATION NE 1/4 NW 1/4 Sec 87 T 22N N/S R 19 E Washoe County
 PERMIT NO. 079-382-25 Red Rock Estates # 85 lot C
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	9	8
Brown sandy clay		9	29	20
Cemented granite sands		29	56	27
Brown sandy clay		56	73	17
Soft zone (NO WATER)		73	79	6
Brown sandy clay		79	145	66
Soft zone (APPROX. 2 GPM) X		145	146	1
Brown sandy clay		146	155	9
Soft zone (approx. 2 GPM) X		155	162	7
Brown clay		162	186	24
Soft zone (approx. 6 GPM) X		186	192	6
Brown clay		192	216	24
Soft zone (approx. 6 GPM) X		216	220	4
Brown clay with granite sands		220	225	5

8. WELL CONSTRUCTION
 Depth Drilled 225 Feet Depth Cased 225 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
 From 8 5/8 Inches To 225 Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>225</u>

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 147 feet to 167 feet
 From 197 feet to 217 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 51 feet
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 225 feet

9. WATER LEVEL
 Static water level 61 feet below land surface
 Artesian flow _____ G.P.M. 16 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne C. Hedeman
 By driller performing actual drilling on site or contractor
 Date November 30, 1994

Date started 11-28-94, 19_____
 Date completed 11-30-94, 19_____
 RECEIVED BY ENGINEERS OFFICE
 94 DEC -2 AM 11:23

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>16</u>		