

OFFICE USE ONLY  
Log No. \_\_\_\_\_  
Permit No. \_\_\_\_\_  
Basin 108

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_  
ADDRESS AT WELL LOCATION 14 Sunny Grove DR. Yerington, Nev. 89447

1. OWNER C. V. Ward  
MAILING ADDRESS 21 Maple DR. Yerington, Nev. 89447  
2. LOCATION NW 1/4, SW 1/4 Sec. 9 T. 12 S. R. 25 E. Lyon County  
PERMIT NO. 12-231-03  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Sandy		0	5	5
Coarse Sand - Small				
Gravel - Few Rock		5	58	53
Coarse Sand - Gravel		58	74	16
Coarse Sand - Gravel				
Clay		74	96	22
Coarse Sand - Gravel				
Few Rock		96	128	32
Clay - Gravel		128	140	12
Coarse Sand - Gravel				
Gravel	X	140	159	19

8. WELL CONSTRUCTION  
Depth Drilled ~~159~~ 160 Feet Depth Cased ~~159~~ 160 Feet  
HOLE DIAMETER (BIT SIZE)  
From 10 5/8 Inches To \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>159</u>

Perforations:  
Type perforation Sawed  
Size perforation 3/32 x 3" x 6 Rows  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 50 feet to 159 feet

9. WATER LEVEL  
Static water level 48 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Ogden Bros Drilling Contractor  
Address 162 N. ByBee Lane Yerington Nev 89447 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 15646  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 11-8-94

Date started 10-21 1994  
Date completed 10-27 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Bailed</u>	<u>20</u>	<u>70</u>	<u>1/2 HR</u>
<u>AIR LIFT</u>	<u>30</u>	<u>160' AIR Line</u>	<u>2 HR</u>