WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46054
Permit No.
Basin 108

NOTICE OF INTENT NO.

1. OWNER Joe + Emogean Roderick
MAILING ADDRESS 821 Whitney Way Gardnerville, Nv. 89410
ADDRESS AT WELL LOCATION 10 Mesa DR. Yerington, Nev, 89447

2. LOCATION SW ¼ SE ¼ Sec. 29 T. 14 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) 04-083-03 (Parcel No.) Lot 23 Copper Hills Est. (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Sandy with Gravel		0	3	3
Fill - Sand - Gravel Few Rock		3	45	42
Clay + Fill above		45	52	7
Fill - Sand - Gravel Few Rock		52	92	40
Fill above + Clay		92	115	22
Fill - Sand - Gravel Few Rock		115	135	20
Fill above + clay		135	140	5
Fill - Sand - Gravel Few Rock	X	140	159	19

Date started June 16, 1994
Date completed June 20, 1994

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	30	5	½ HR
AIR LIFT	50	160' air Line	2 HRS

8. WELL CONSTRUCTION
Depth Drilled 159 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/8 Inches		0 Feet	159 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	159

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" X 6 Rows
From 139 feet to 159 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 159 feet

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N Pybee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-5-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627