X

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. [redacted] 46656
Permit No.
Basin 108

NOTICE OF INTENT NO. 17148

1. OWNER Grover F. Glasser
MAILING ADDRESS #10 amber
Yerington, Nev 89447

ADDRESS AT WELL LOCATION 107 Jags Circle
Yerington, Nev 89447

2. LOCATION NW ¼ NW ¼ Sec. 14 T. 13 N/S R. 25 E. Lyon County
PERMIT NO. Issued by Water Resources
APN 14-481-18 Parcel No.
Lot 8 Grover F. Glasser Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Fine To Coarse Sand - Small Gravel		4	38	34
Brown Clay - Gravel		38	50	12
Bluish Gray Clay - Gravel		50	53	3
Coarse Sand - Gravel		53	70	17
Brown Clay - Sand - Gravel		70	75	5
Fine To Coarse Sand		75	84	9
Coarse Sand - Gravel - Rock		84	94	10
Coarse Sand - Gravel		94	110	16
Brown Clay - Small Gravel		110	115	5
Coarse Sand - Small Gravel		115	128	13
Coarse Sand - Gravel - Rock		128	140	12
Coarse Sand - Gravel	X	140	159	19

Date started 8-3, 1994
Date completed 8-5, 1994

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	25	2	½ HRS
	35	5	
AIR LIFT	100+	—	2 HRS

8. WELL CONSTRUCTION
Depth Drilled 159 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	159 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.72	.188	+1	159

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3 x 6 Rows
From 139 feet to 159 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 159 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling Contractor
Address 162 N. Bybee Lane Contractor
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] By driller performing actual drilling on site or contractor
Date 8-23-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627