WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4465
Permit No.
Basin 108

NOTICE OF INTENT NO.

1. OWNER Lee Davidson
MAILING ADDRESS P.O. Box 61 Yerington Nev 89447
ADDRESS AT WELL LOCATION 138 N. By Bee Lane Yerington, Nev. 89447

2. LOCATION NW ¼ SW ¼ Sec. 23 T. 14 N/S R. 26 E. Lyon County
PERMIT NO. Issued by Water Resources | 14-332-10 Parcel No. | Lot 29 Ogden Parcels Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Open Hole | | 0 | 47 | 47 |
| Fill in Casing-Sand-Small Gravel | | 47 | 54 | 7 |
| Start Drilling | | 54' | | |
| Coarse Sand-Clay | | 54 | 60 | 6 |
| Brown Clay | | 60 | 78 | 18 |
| Coarse Sand-Clay | | 78 | 85 | 7 |
| Coarse Sand | | 85 | 87 | 2 |
| Brown Clay | | 87 | 107 | 20 |
| Fine To Coarse Sand | | 107 | 120 | 13 |
| Coarse Sand - Gravel | X | 120 | 142 | 22 |

Date started 6-7, 19 94
Date completed 6-10, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| AIR LIFT | 100 | 120' air line | 3 HRS |

8. WELL CONSTRUCTION
Depth Drilled 142 Feet Depth Cased 143'3" Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 7⅞ Inches | | 54 Feet | 142 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 5" | 9.66 | .188 | +1.5 | 142 |

Perforations:
Type perforation Sawed 5
Size perforation 3/32 x 3" x 5 Rows
From 122 feet to 142 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 142 feet

9. WATER LEVEL
Static water level 25' feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. By Bee Lane Yerington Nev 89447 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed L. Ogden (By driller performing actual drilling on site or contractor)
Date 11-22-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627