WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46658
Permit No.
Basin 108

NOTICE OF INTENT NO.

1. OWNER Kurt Myers
MAILING ADDRESS 30 Cottonwood Lane
Yerington Nev 89447

ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼ SW ¼ Sec. 12 T. 13 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) 04-311-02 (Parcel No.) Lot 26 Cottonwood Terrace Estates Extension (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil Clayish Sand		0	6	6
Fine To Coarse Sand		6	14	8
Coarse Sand - Clay		14	16	2
Coarse Sand - Gravel		16	29	13
Brown Clay		29	30	1
Coarse Sand - Gravel		30	57	27
Brown Clay		57	58	1
Bluish Gray Clay		58	64	6
Coarse Sand - Gravel		64	68	4
Brown Clay		68	74	6
Brown Clay - Gravel		74	75	1
Brown Clay		75	76	1
Coarse Sand - Gravel		76	96	20
Brown Clay - Gravel		96	102	6
Coarse Sand - Gravel	X	102	159	57

Date started 5-9, 1994
Date completed 5-16, 1994

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	25	5	½ HRS
AIR LIFT	60	140' air Line	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 159 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	159

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 139 feet to 159 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 159 feet

9. WATER LEVEL
Static water level 21 feet below land surface
Artesian flow G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N By Bee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-27-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627