

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Jim Hill ADDRESS AT WELL LOCATION Same
MAILING ADDRESS 25 Cottonwood Lane
Yerington, Nev. 89447
2. LOCATION N10 1/4 SW 1/4 Sec. 12 T. 13 N. R. 25 E. 20N County _____
PERMIT NO. 04-301-04 Parcel No. Lot 18 Cottonwood Terrace Estates Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Clayish Sand		0	7	7
Fine to Coarse Sand		7	10	3
Brown Clay		10	12	2
Coarse Sand - Gravel		12	28	16
Brown Clay		28	30	2
Coarse Sand - Small Gravel		30	50	20
Brown Clay		50	54	4
Brown Clay - Gravel		54	58	4
Bluish gray Clay		58	64	6
Fine to Coarse Sand		64	70	6
Brown Clay - Gravel		70	74	4
Coarse Sand - Gravel	X	74	159	85

8. WELL CONSTRUCTION
Depth Drilled 159 Feet Depth Cased 160 Feet
HOLE DIAMETER (BIT SIZE)
From 0 Feet To 159 Feet
Inches..... Feet.....
Inches..... Feet.....
Inches..... Feet.....

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.185</u>	<u>+1</u>	<u>159</u>

Perforations:
Type perforation Sawed
Size perforation 3 1/2 x 3" x 6 Rows
From 159 feet to 159 feet
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet

Surface Seal: Yes No Seal Type:
Depth of Seal 100 Neat Cement
Placement Method: Pumped Poured Cement Grout Concrete Grout
Gravel Packed: Yes No
From 100 feet to 159 feet

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow - G.P.M. - P.S.I.
Water temperature Cold °F Quality Good

Date started 5-4, 1994
Date completed 5-19, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>ROCKET</u>	<u>25</u>	<u>3</u>	<u>1/2 HRS</u>
<u>AIR LIFT</u>	<u>100</u>	<u>140' air line</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling Contractor
Address 162 N. D. Bee Lane Contractor
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Lay Ogden
By driller performing actual drilling on site or contractor
Date 11-22-94