

OFFICE USE ONLY
Log No. 46660
Permit No. _____
Basin 108

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Ray A. Bellew ADDRESS AT WELL LOCATION 23 Watkins Way
MAILING ADDRESS 4950 Bear Valley Road Yerington Nev 89447
Mariposa, Ca. 95338

2. LOCATION SW 1/4 NW 1/4 Sec 3 T 13 R 26 E Lyon County
PERMIT NO. 14-631-11 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Clay		0	3	3
Coarse Sand - Clay		3	5	2
Clay + Sand Strata		5	40	35
Fine Sand		40	45	5
Coarse Sand		45	50	5
Clay + Gravel		50	62	12
Coarse Sand - Gravel		62	67	5
Clay - Gravel		67	80	13
Coarse Sand - Gravel		80	96	16
Sand - Gravel - Rock	X	96	152	56

94 1000 - 1 All 134
STATE ENGINEER

8. WELL CONSTRUCTION
Depth Drilled 152 Feet Depth Cased 153 Feet

HOLE DIAMETER (BIT SIZE)
From 10 5/8 Inches To 0 Feet 152 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.185</u>	<u>71</u>	<u>152</u>

Perforations:
Type perforation Sawed
Size perforation 3 1/2 x 3" x 6 Rows
From 132 feet to 152 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 152 feet

9. WATER LEVEL
Static water level 42 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Good

Date started 2-2, 1997
Date completed 2-8, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailed</u>	<u>20</u>	<u>10</u>	<u>1 1/2 HRS</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden Bros Drilling Contractor
Address 162 N. B. Bee Lane Contractor
Yerington Nev 89447

Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634

Signed [Signature]
By driller performing actual drilling on site or contractor
Date 11-27-94