

Log No. 4666a
Permit No. 107
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Joe Carbal ADDRESS AT WELL LOCATION 20 Valley View DR
MAILING ADDRESS P.O. Box 32 Wellington, Nev. 89444
2. LOCATION NE 1/4 NE 1/4 Sec 11 T 10 N R 23 E Lyon County
PERMIT NO. 10-661-09 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Open Hole		0	112	112
Fill in Pipe-Rocks		112	130	18
Fill in Pipe-Sand-Clay		130	138	8
Clay + Rock		138	150	12
Coarse Sand-Rock	X	150	165	15
Clay-Rock		165	170	5
Coarse Sand-Rock	X	170	190	20
Clay-Rock		190	193	3
Coarse Sand-Rock	X	193	197	4
Old well 8 7/8" 138' Deep 50' Seal				

DEC -1 AM 1:34
RECEIVED
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 197 Feet Depth Cased 198 Feet

HOLE DIAMETER (BIT SIZE)
7 7/8 Inches From 138 Feet To 197 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.72</u>	<u>.188</u>	<u>+1</u>	<u>197</u>

Perforations:
Type perforation Sawed
Size perforation 4 1/2 x 3" x 6 Rows
From 117 feet to 137 feet
From 177 feet to 197 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal _____ Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 0 feet to 197 feet

Date started 94 12-7 1993
Date completed 12-14 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
AIR LIFT	<u>20</u>	<u>180' AIR Line</u>	<u>1 HRS</u>
Bailed	<u>20</u>	<u>8</u>	<u>1/2 HRS</u>

9. WATER LEVEL
Static water level 92' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling Contractor
Address 162 N. By Bee Lane Contractor
Wellington Nev 89447
Nevada contractor's license number 15646
issued by the State Contractor's Board
Nevada driller's license number issued by the 634
Division of Water Resources, the on-site driller
Signed Joe Carbal
By driller performing actual drilling on site or contractor
Date 11-29-94