

OFFICE USE ONLY  
 Log No. 46568  
 Permit No. \_\_\_\_\_  
 Basin 08

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Richard Weber ADDRESS AT WELL LOCATION 125 Penrose Lane  
 MAILING ADDRESS 125 Penrose Lane Yerington Nev 89447  
 2. LOCATION NW 1/4 SE 1/4 Sec. 11 T. 14 S. R. 25 E. Lyon County  
 PERMIT NO. 14-201-05 ROS 94001  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other unknown

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Place neat cement				
From 75' to Top				
30 gals. water flow over top approx				
12 Bags poured				
31' water level @ time of pour				
Casing very thin & rusty well had sand & low yield				

8. WELL CONSTRUCTION

Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	Inches	Feet
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7"	-	.125	16"	75

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 6-2, 1994  
 Date completed 6-2, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level 31 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality Poor

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden Bros Drilling Contractor  
 Address 162 N. DyBee Lane Contractor  
Yerington Nev 89447  
 Nevada contractor's license number issued by the State Contractor's Board 15646  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634  
 Signed L. Ogden  
 By driller performing actual drilling on site or contractor  
 Date 6-3-94