WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46668
Permit No.
Basin 071

NOTICE OF INTENT NO. 29935

1. OWNER Greg Caffee
MAILING ADDRESS P.O. Box 1903
Winnemucca NV. 89446

ADDRESS AT WELL LOCATION ½ mile north of Silva Road on VanDiest. No physical address at this time.

2. LOCATION NW ¼ NW ¼ Sec. 25 T. 34 N/S R 37 E Pershing County

PERMIT NO. NA (Issued by Water Resources) | 9-190-18 (Parcel No.) | NA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	15	
Gravel W/S Rock		15	50	
Clay and Sand		50	60	
Cemented rock W/S Gravel		60	80	
Clay and Sand		80	90	
Gravel W/S Clay		90	120	

'94 DEC 12 P2:29 STATE ENGINEER'S OFFICE

Date started 12-2-94, 19
Date completed 12-5, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	N/A	4hr.

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10" Inches		0 Feet	120 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	N/A	188	+1	120

Perforations:
Type perforation Factory
Size perforation 1/8 by 3"
From 80 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 120 feet to 50 feet

9. WATER LEVEL
Static water level 62 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Dave McNinch (Contractor)
Address 8005 Mc Ninch RD. (Contractor)
Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 5437
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
Signed Gerald Lee Mowry (By driller performing actual drilling on site or contractor)
Date 11/9/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627