



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27046
 ADDRESS AT WELL LOCATION 350 Sunrise Terrace

1. OWNER Hammoured Homes ADDRESS AT WELL LOCATION Fallon
 MAILING ADDRESS 178 Witter Rd Fallon
 2. LOCATION SW 1/4 SW 1/4 Sec. 19 T 19 N/S R. 29 E Churchill County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand	✓	0	17	17
Brown Clay		17	20	3
Brown Sand	✓	20	40	20
Black Sand	✓	40	47	7
Grey Sandy Clay		47	85	38
Brown Sand		85	103	18

'94 OCT 21 P 219
 STATE ENGINEER'S OFF.

8. WELL CONSTRUCTION
 Depth Drilled 103 Feet Depth Cased 103 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
 From 6 Inches To 103 Feet
 From _____ Inches To _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>-.188</u>	<u>71</u>	<u>103</u>

Perforations:
 Type perforation machine slot
 Size perforation .070
 From _____ feet to _____ feet
 From 97 feet to 102 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 12' - 1/2" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started Oct 10 1994
 Date completed Oct 10 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>		<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WELSCO Contractor
 Address Box 888 Fallon Nev. Contractor
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
 Signed Wesley J. Apple
 By driller performing actual drilling on site or contractor
 Date Oct 10-94