



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26604

1. OWNER George Lindell ADDRESS AT WELL LOCATION 424 Lindell Blvd, Gardnerville NV 89410  
 MAILING ADDRESS 424 Lindell Ct, Gardnerville NV 89410  
 2. LOCATION NE 1/4 NE 1/4 Sec. 22 T. 12 S. R. 19 E. Douglas County  
 PERMIT NO. \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED:  New Well,  Replace,  Recondition,  Deepen,  Abandon,  Other \_\_\_\_\_  
 4. PROPOSED USE:  Domestic,  Municipal/Industrial,  Irrigation,  Monitor,  Test,  Stock  
 5. WELL TYPE:  Cable,  Rotary,  RVC,  Air,  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	3	3
Boulders & Sands		3	24	21
Clay		24	32	8
Hard D&S		32	110	78
D&S and Clay		110	145	35
Broken D&S Fractures	XXX	145	180	35

8. WELL CONSTRUCTION  
 Depth Drilled 180' Feet Depth Cased 180' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 1/4 Inches To 30 Feet  
9 1/8 Inches 50 Feet 180 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.03</u>	<u>.184</u>	<u>0</u>	<u>180</u>

Perforations:  
 Type perforation Mill slot  
 Size perforation 3 x 3/32  
 From 160 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement,  Cement Grout,  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped,  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 180 feet

9. WATER LEVEL  
 Static water level 60 feet-below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 15-18 P.S.I.  
 Water temperature Cold °F Quality Good

Date started 10-14, 19 94  
 Date completed 10-17, 19 94

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15-18</u>	<u>40</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AH Pump Co. Contractor  
 Address 5551 Hwy 60 E #3 Carson City NV 89701  
 Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael L. Baker  
 By driller performing actual drilling on site or contractor  
 Date 10-17-1994