

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. \_\_\_\_\_  
Permit No. 105  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26803

1. OWNER Ben Disalvo ADDRESS AT WELL LOCATION 675 Centerville Ln. Gardnerville NV. 89401  
MAILING ADDRESS 675 Centerville Ln. Gardnerville NV. 89401  
2. LOCATION SW 1/4 SW 1/4 Sec. 11 T. 12 S. R. 19 E. Douglas County  
PERMIT NO. 19-230-13 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sands		0	3	3
Coarse Sands & Gravel		3	8	5
Gravel Sands		8	23	15
Coarse Det Sands		23	56	33
Coarse Sands w/ small Clay Balls		56	87	31
Coarse Gravels and River Rock		87	140	53

8. WELL CONSTRUCTION  
Depth Drilled 140 Feet Depth Cased 140 Feet  
HOLE DIAMETER (BIT SIZE)  
From 10 1/4 Inches To 140 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 1/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
Type perforation Mill Slot  
Size perforation 3 x 3/32  
From 120 feet to 140 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 100  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 100 feet to 140 feet

9. WATER LEVEL  
Static water level \_\_\_\_\_ feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. 35+ P.S.I.  
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name A&H Pump Company Contractor  
Address 5551 Hwy 50 E #3 Carson City NV 89201 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 31839  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
Signed Richard Haek  
By driller performing actual drilling on site or contractor  
Date 10-6-94

Date started 10-3 1994  
Date completed 10-6 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35+</u>	<u>20</u>	<u>3 HRS</u>

'94 OCT 13 P1 08  
STATE ENGINEERS OFFICE