X

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No.
Permit No.
Basin 105

NOTICE OF INTENT NO. 26802

1. OWNER Harlan Anderson
MAILING ADDRESS 785 Centerville Ln. Gardnerville NV - 89401
ADDRESS AT WELL LOCATION 785 Centerville Ln Gardnerville NV. 89401

2. LOCATION NW ¼ NW ¼ Sec. 18 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 19-230-07 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay/Sands		0	12	12
Gray Sands		12	19	7
Brown Gummy Clay w/ Large Gravels		19	65	46
DG Sands w/Lg Gravels		65	90	25
Large River Gravels w/ Clay Seams	XX	90	140	50

'94 OCT 13 P1:08 STATE ENGINEER'S OFFICE

Date started 10-1, 19 94
Date completed 10-4, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
354	25	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.34	.188	0	140

Perforations:
Type perforation Mill Slot
Size perforation 3X3/32
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 100' feet to 140' feet

9. WATER LEVEL
Static water level 2' feet below land surface
Artesian flow G.P.M. 354 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. (Contractor)
Address 3551 Hwy 50 E #3 Carson City NV. 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed (By driller performing actual drilling on site or contractor)
Date 10-4-94

USE ADDITIONAL SHEETS IF NECESSARY

(R6-9-91) (O)-627