

XX

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

Log No. 46703  
Permit No. 105  
Basin

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26806

1. OWNER Ken Olson ADDRESS AT WELL LOCATION 1784 Solitude  
MAILING ADDRESS 447 P.O. Box 1147 Garberville NV. 89410  
Minden NV. 89428 D2 12 N  
2. LOCATION SE 1/4 SE 1/4 Sec. 35 T. 15 S. R. 20 E. Douglas County  
PERMIT NO. 23-480-60 APN (NEW) 1220-02-001-019  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>HARD Pack Clay</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>Coarse Gravels and Cobbles</u>		<u>6</u>	<u>58</u>	<u>52</u>
<u>Brown Sandy Clay</u>		<u>58</u>	<u>74</u>	<u>16</u>
<u>Coarse Gravels</u>		<u>74</u>	<u>98</u>	<u>24</u>
<u>Brown Clay</u>		<u>98</u>	<u>165</u>	<u>67</u>
<u>Small Coarse Sands &amp; Clay</u>		<u>165</u>	<u>183</u>	<u>18</u>
<u>Brown Gummy Clay</u>		<u>183</u>	<u>205</u>	<u>22</u>
<u>Broken Gravels</u>	<u>XXX</u>	<u>205</u>	<u>240</u>	<u>35</u>

94 OCT 26 P 2 03  
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
Depth Drilled 240' Feet Depth Cased 240' Feet  
HOLE DIAMETER (BIT SIZE)  
From 10 1/4 Inches 0 Feet 240 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>240</u>

Perforations:  
Type perforation Mill Slot  
Size perforation 3 X 3/32  
From 220' feet to 240' feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 65'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 55' feet to 240' feet

9. WATER LEVEL  
Static water level 85' feet below land surface  
Artesian flow G.P.M. 30 P.S.I.  
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name AH Pump Company  
Address 655 Hwy 50 E #3  
Carson City NV. 89701  
Nevada contractor's license number 31839  
issued by the State Contractor's Board.  
Nevada driller's license number issued by the 1905  
Division of Water Resources, the on-site driller.  
Signed Michael D. Haek  
By driller performing actual drilling on site or contractor  
Date 10-24-94

Date started 10-20, 1994  
Date completed 10-23, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>60</u>	<u>3 HRS</u>